NOVA Parks Northern Virginia Regional Park Authority 5400 Ox Road Fairfax Station, Virginia 22039



ADDENDUM #1

SITE DEVELOPMENT AND UTILITY INSTALLATION FOR 3200 SF STORAGE BUILDING

November 29, 2023

This Addendum shall become part of the Contract Documents and shall modify the bid documents, including any past addenda, as indicated below.

Bidders should acknowledge receipt of this Addendum in the appropriate space on the Form of Proposal.

- 1. The attached <u>Sheet 26A Landscape Plan Details</u> shall be added to the bid documents and all work on this plan sheet shall be included in the Base Bid amount.
- 2. The waterline shall be Copper Type K, unless Municipex is proposed.
- 3. The sanitary sewer laterals shall be PVC DR 25 (per Fairfax County PFM Section 10-0103.7.A)

END OF ADDENDUM