



## **ADDENDUM NUMBER TWO (2)**

For  
**Meadowlark Botanical Garden  
Greenhouse Construction**

Addendum Date:  
April 23, 2019

### GENERAL

- A. This addendum shall become part of the Contract Documents and modify the bidding documents including past addenda as indicated below.
- B. Bidders should acknowledge receipt of this Addendum in the appropriate space on the Form of Proposal.
- C. This Addendum consists of one (1) typed page of corrections /additions to the Contract Documents and three (3) revised plan sheets.

- 
1. The sanitary lateral connection has been revised as per the attached plan sheet CSK-001. Note that there is no longer a requirement for a manhole to be installed at the connection point. The depth of the existing sanitary line at the connection point is approximately 3 feet below existing grade.
  2. The electric service being provided by Dominion will be single phase. The original plans incorrectly indicated three phase equipment and connections in various locations. Electric plans are revised as per the clouded areas on the attached plans sheets E2.1 and E6.1.
  3. The diameter of the underground electric conduit between meter and building panel shall be 4 inches as noted on E6.1. This conduit does not need to be encased in concrete.
  4. Site plan note #5 on sheet E2.1 is deleted. There shall be no requirement to install two conduits back to telephone room in main building.

**END OF ADDENDUM**