



ADDENDUM NUMBER THREE (3)

For
**Meadowlark Botanical Garden
Greenhouse Construction**

Addendum Date:
April 25, 2019

GENERAL

- A. This addendum shall become part of the Contract Documents and modify the bidding documents including past addenda as indicated below.
- B. Bidders should acknowledge receipt of this Addendum in the appropriate space on the Form of Proposal.
- C. This Addendum consists of one (1) typed page of corrections /additions to the Contract Documents.

-
1. The project site plan currently notes the water meter to be located next to the greenhouse. NOVA Parks is amending the site plan to relocate the meter to be immediately adjacent to the proposed wet tap and existing water main. The Contractor shall be responsible for installing the water service line from the meter to the greenhouse.
 2. The existing sanitary main on site is constructed of PVC.

END OF ADDENDUM